

VAULT AND COVER  
PER CWD-800-1 & 800-2 (12)



- ① DRY--PACK PIPE OPENINGS.
- ② SUPPORT COMPOUND METER ON CONCRETE PAD WITH CONCRETE BLOCK.
- ③ CONTRACTOR SHALL INSTALL ALL PIPE, FITTINGS, AND MATERIALS BETWEEN THE TAPPING GATE AND "PIPING BY CUSTOMER", INCLUDING TEMPORARY CONNECTION AT INFLUENT VALVE.
- ④ ADJUST VAULT AND COVER TO MEET SIDEWALK AND CURB GRADE. PAINT PER SECTION 310.
- ⑤ PROVIDE JOINT RESTRAINTS PER CONSTRUCTION SPECIFICATIONS.
- ⑥ POUR PCC 480-C-2000 CONCRETE THRUST COLLAR AGAINST WALL OF VAULT.

TYPICAL DIMENSIONS				
SERVICE SIZE	A	B	C	D
3 IN.	9"	24"	29"±	11"
4 IN.	9"	24"	24±	11 1/2"
6 IN.	10 1/2"	36 1/2"	13"±	12 1/2"